



EC DECLARATION OF CONFORMITY

The manufacturer **LAE electronic Srl**, registered offices at *via Padova, 25 Oderzo ITALY*, on the basis of the test results obtained using appropriate standards, states that the following product:

Name: timer-counter
Model(s): **TIMER122D(.)**
Version(s): ../1 - 3; ..all

meets the essential requirements provided by:

Low Voltage Directive EEC 73/23 - 93/68
EMC Directive EEC 89/336 - 93/68 - 93/97

Standards and levels used:

EN60730-1; EN60730-2-9

EN50081-1:

Emissions

EN55022

class B

EN50082-1:

Electrostatic Discharge	EN61000-4-2 / IEC1000-4-2	- LEVEL IV
RF EM Field	EN61000-4-3 / IEC1000-4-3	- LEVEL III
Fast Transients	EN61000-4-4 / IEC1000-4-4	- LEVEL IV
Surges	EN61000-4-5 / IEC1000-4-5	- LEVEL III
RF Common Mode	EN61000-4-6 / IEC1000-4-6	- LEVEL III
Voltage Dips/Interruptions	EN61000-4-11 / IEC1000-4-11	

Oderzo, 15/05/1997

Franco Perissinotto
Test Department